



>INTERCEPTION SYSTEMS AND ACCESSORIES

> MASTS AND ANCHORAGES

> MASTS FOR ATTACHING TO WALL OR STRUCTURE

Elevation up to 8 m. For attachment using 2 anchorage supports, except those which are 8 m high, in which case 3 anchorage supports are needed. The distance between supports must be 60 cm. In atmospheres with a high level of corrosion, the use of stainless steel masts is recommended.



■ AT-066A (SS - stainless steel)
■ AT-056A (GS - galvanized steel)

Reference	Model	Dimensions	Includes	Material	Weight (kg)
AT-051A	1 m mast	$\varnothing 1\frac{1}{2}'' \times 1 \text{ m}$	1 section x 1 m	Galvanized steel	3.3
AT-052A	2 m mast	$\varnothing 1\frac{1}{2}'' \times 2 \text{ m}$	1 section x 2 m	Galvanized steel	6.6
AT-053A	3 m mast	$\varnothing 1\frac{1}{2}'' \times 3 \text{ m}$	1 section x 3 m	Galvanized steel	10.0
AT-050A	4 m mast	$\varnothing 1\frac{1}{2}'' \times 4 \text{ m}$	2 sections x 2 m	Galvanized steel	13.0
AT-056A	6 m mast (2 sections)	$\varnothing 1\frac{1}{2}'' \times 6 \text{ m}$	2 sections x 3 m	Galvanized steel	20.0
AT-057A	6 m mast (3 sections)	$\varnothing 1\frac{1}{2}'' \times 6 \text{ m}$	3 sections x 2 m	Galvanized steel	20.0
AT-058A	8 m mast	$\varnothing 2'' - \varnothing 1\frac{1}{2}'' \times 8 \text{ m}$	3 sections x 3 m	Galvanized steel	35.0
AT-060A	1 m mast	$\varnothing 1\frac{1}{2}'' \times 1 \text{ m}$	1 section x 1 m	Stainless steel	3.0
AT-062A	2 m mast	$\varnothing 1\frac{1}{2}'' \times 2 \text{ m}$	1 section x 2 m	Stainless steel	6.0
AT-063A	3 m mast	$\varnothing 1\frac{1}{2}'' \times 3 \text{ m}$	1 section x 3 m	Stainless steel	9.0
AT-085A	4 m mast	$\varnothing 1\frac{1}{2}'' \times 4 \text{ m}$	2 sections x 2 m	Stainless steel	12.0
AT-066A	6 m mast (2 sections)	$\varnothing 1\frac{1}{2}'' \times 6 \text{ m}$	2 sections x 3 m	Stainless steel	18.0
AT-067A	6 m mast (3 sections)	$\varnothing 1\frac{1}{2}'' \times 6 \text{ m}$	3 sections x 2 m	Stainless steel	18.0
AT-068A	8 m mast	$\varnothing 2'' - \varnothing 1\frac{1}{2}'' \times 8 \text{ m}$	3 sections x 3 m	Stainless steel	30.0

Complies with UNE 21186, NF C 17-102